

Consulting Analytical & Industrial Chemists
 Specialists in Water & Waste Water Treatment
 Telephone (021)448 6340/1
 After Hours (021)712 0940
 Telefax (021)448 6342
 e-Mail Address :
 info@alabbott.co.za



No. 1, Vine Park
 Vine Road
 7925
 P.O. Box 483
 WOODSTOCK, CAPE
 7915

Certificate of Analysis

WITZENBERG MUNICIPALITY : BID 08/2/12/30&32

Witzenberg Municipality Reticulation Waters

1 : Reservoir, Final, Post-Chlorination ex Ceres

DATE SAMPLED : 2019/08/07

DATE RECEIVED : 2019/08/08

**DATE ANALYSIS
 COMMENCED :** 2019/08/08

OUR REF. : 2019/08/07/21999

REPORT NO. : 4486

	Sample Number	21999	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
19	pH (at 25 °C)	5.00	≥5 - ≤ 9.7 Operational
9	Conductivity (mS/m) (at 25 °C)	5.0	≤170 Aesthetic
27	Turbidity (NTU)	0.96	≤1 Operational : ≤5 Aesthetic
97	Colour (mg/l as Pt)	6	≤15 Aesthetic
7	Total Dissolved Solids (mg/l)	36	≤1200 Aesthetic
92	Iron (µg/l as Fe)	32	≤300 Aesthetic ≤2000 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Aluminium (µg/l as Al)	36	≤300 Operational
66	Free Chlorine (mg/l)	0.74	≤5 Chronic Health
66	Total Chlorine (mg/l)	1.5	N/A
84	E.coli (count per 100 ml)	<1	Not Detected
85	Total Coliform Bacteria (count per 100 ml)	<1	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	<1	≤1000 Operational

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (021)712 0940
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.3

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

WITZENBERG MUNICIPALITY : BID 08/2/12/30&32

Witzenberg Municipality Reticulation Waters

1 : Reservoir, Final, Post-Chlorination ex Ceres

DATE SAMPLED : 2019/08/07
DATE RECEIVED : 2019/08/08
DATE ANALYSIS
COMMENCED : 2019/08/08

OUR REF. : 2019/08/07/21999
REPORT NO. : 4486

	Sample Number	21999	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
13 August 2019

TO: WITZENBERG MUNICIPALITY
P O Box 44
CERES
6835

Att: S. FARMER

Sampler : V. Opperman (ALA)

This report relates only to the samples tested and is issued subject to the company's standard terms and conditions of business.