

Test Report

Client: Witzenberg Municipality
Address: 50 Voortrekker Street, Ceres, 6835
Report no: 236880
Project: Witzenberg Drinking Water

Date of report: 07 October 2025
Date accepted: 01 October 2025
Date completed: 07 October 2025
Date received: 01 October 2025

Lab no:							356308
Date sampled:							01-Oct-25
Aquatico sampled:							Yes
Sample type:					Uncertainty of measurement %	SANS 241-1:2015	Water
Locality description:							Wolseley Water Treatment Works Final
Analyses			Unit	Method			
A	AQCL	pH @ 25°C	pH	ALM 20	2.33	5 - 9.7	5.10
A	AQCL	Electrical conductivity (EC) @ 25°C	mS/m	ALM 20	4.92	< 170	2.33
A	AQCL	Total Dissolved solids @ 180°C	mg/l	ALM 24	9.42	< 1200	16
A	AQL	Acid Soluble Aluminium (Al)	mg/l	ALMA 31	7.08	< 0.3	0.040
A	AQL	Acid Soluble Iron (Fe)	mg/l	ALMA 31	7.16	< 0.3	<0.004
A	AQL	Acid Soluble Manganese (Mn)	mg/l	ALMA 31	6.34	< 0.1	0.002
A	AQCL	E.coli	CFU/100ml	ALM 40	7.74	0	<1
A	AQCL	Total coliform	CFU/100ml	ALM 40	7.76	< 10	<1
A	AQCL	Heterotrophic plate count	CFU/ml	ALM 45	2.22	< 1000	1
A	AQCL	Turbidity	NTU	ALM 21	5.9	< 1	0.573
N	AQCL	Total Chlorine (Cl ₂)	mg/l	ALM 23	5.94		0.39
A	AQCL	Free chlorine (Cl ₂)	mg/l	ALM 23	5.94	< 5	0.37
A	AQCL	True Colour	mg/l Pt-Co	ALM 22	8.74	< 15	<5.00

A: Accredited N: Not accredited Sub: Sub-contracted NR: Not requested RTF: Results to follow NATD: Not able to determine ATR: Alternative Test Report test report ; Results relate only to the items sampled and tested ; Results reported against the limit of detection; Results marked "Not SANAS Accredited" in this report are not covered by the Scope of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

AQL: Aquatico Laboratories ; AQCL: Aquatico Cape Laboratories